



NOTES:

- CATCH BASINS SHALL BE CONSTRUCTED IN ACCORDANCE WITH SECTION 7-05 OF THE WSDOT/APWA STANDARD SPECIFICATIONS, UNLESS OTHERWISE SHOWN ON PLANS.
- HANDHOLDS IN ADJUSTMENT SECTION SHALL HAVE 3\" MIN. CLEARANCE. STEPS IN CATCH BASIN SHALL HAVE 6\" MIN. CLEARANCE. SEE DWG. NO. 2-005, CATCH BASIN DETAILS. HANDHOLDS SHALL BE PLACED IN ALTERNATING GRADE RINGS OR LEVELING BRICK COURSE WITH A MIN. OF ONE HANDHOLD BETWEEN THE LAST STEP AND TOP OF THE FINISHED GRADE.
- ALL REINFORCED CAST-IN-PLACE CONCRETE SHALL BE CLASS 4000. ALL PRECAST CONCRETE SHALL BE CLASS 4000.
- PRECAST BASES SHALL BE FURNISHED WITH CUTOUTS OR KNOCKOUTS. KNOCKOUTS SHALL HAVE WALL THICKNESS OF 2\" MIN. TO 2.5\" MAX. UNUSED KNOCKOUTS NEED NOT BE GROUTED IF WALL IS LEFT INTACT. PIPES SHALL BE INSTALLED ONLY IN FACTORY KNOCKOUTS UNLESS OTHERWISE APPROVED BY THE ENGINEER.
- KNOCKOUT OR CUTOUT HOLE SIZE SHALL EQUAL PIPE OUTER DIAM. PLUS CATCH BASIN WALL THICKNESS. MAX. HOLE SIZE SHALL BE 36\" FOR 48\" CATCH BASIN, 42\" FOR 54\" C.B., 48\" FOR 60\" C.B., 60\" FOR 72\" C.B., 84\" FOR 96\" C.B. MIN. DISTANCE BETWEEN HOLES SHALL BE 8\" FOR 48\", 54\", AND 60\" C.B.; 12\" FOR 72\" AND 96\" C.B.
- CATCH BASIN FRAMES AND GRATES OR COVERS SHALL BE IN ACCORDANCE WITH SEC. 7.05.
- MATING SURFACES SHALL BE FINISHED TO ASSURE NON-ROCKING FIT WITH ANY COVER POSITION.
- ALL BASE REINFORCING STEEL SHALL HAVE A MIN. YIELD STRENGTH OF 60,000 PSI AND BE PLACED IN THE UPPER HALF OF THE BASE WITH 1\" MIN. TO 2.5\" MAX. CLEARANCE.
- MIN. SOIL BEARING VALUE SHALL EQUAL 3,300 POUNDS PER SQUARE FOOT.
- FOR DETAILS SHOWING LADDER, STEPS, HANDRAILS AND TOP SLABS, SEE DWG. NO. 2-005.
- SEE THE WSDOT/APWA STANDARD SPECIFICATIONS SEC. 7-05.3 FOR JOINT REQUIREMENTS.